



CURB EXPANSION JOINT DOWEL DETAIL

NOTES:

1. ALL WORK AND MATERIAL SHALL CONFORM TO ASTM A615, A615M, C309 AND D1752. BROOM FINISH EXPOSED SURFACE.
2. CONTROL JOINT SPACING SHALL NOT EXCEED 10'-0'.
3. EXPANSION JOINTS AS PER STANDARD ASTM D-1752.
4. EXPANSION JOINT INTERVALS NOT TO EXCEED 40'-0" FOR ALL CURBS/METHODS.
5. ALL CURBS SHALL HAVE A MINIMUM OF 4" OF COMPACTED FLEXIBLE BASE BETWEEN BOTTOM OF CURB AND TOP SUBGRADE THAT SHALL EXTEND A MIN OF 18" BEHIND BACK OF CURB.
6. ALL CURBS SHALL CONFORM TO THESE DETAILS INDEPENDENT OF THE CONSTRUCTION METHODS USED.

	CITY OF HUTTO CONSTRUCTION STANDARDS AND DETAILS	DRAWING NO. ST08
	SPILL AND CATCH CURB	UPDATED: 02/01/2019
	ENGINEERING & PUBLIC WORKS	DRAWN BY: BB
		SCALE: N.T.S.
		FILE NAME: ST08.DWG